


# EMMETT SMITH & ASSOCIATES, ARCHITECT, P.C.

P.O. Box 171, Guntersville, AL 35976  
(205) 531-3749 \* (256) 293-3451  
emmettsmitharchitect@yahoo.com



## **ADDENDUM TO BID DOCUMENTS ADDENDUM NUMBER: ONE**

DATED: 09/25/17

### **PARTIAL RENOVATION OF LOWER FLOOR AT THE GUNTERSVILLE MUNICIPAL BUILDING FOR THE CITY OF GUNTERSVILLE, AL**

The following modifications, additions and/or changes shall be incorporated into and shall become a part of the bid documents and specifications for the PARTIAL RENOVATION OF LOWER FLOOR AT THE GUNTERSVILLE MUNICIPAL BUILDING FOR THE CITY OF GUNTERSVILLE, AL, located in Guntersville, Alabama. This Addendum is located in the City of Guntersville's website.

Each change is identified in the following order:

THE APPLICABLE SPECIFICATION NUMBER OR DRAWING NUMBER AND TITLE.  
THE APPLICATION SECTION OR PARAGRAPH.

- THE SCOPE OF THE CHANGE:
  - The description of the change, addition or modification

#### **THE CHANGES ARE AS FOLLOWS:**

DRAWING – A-GM-03 - ENLARGED NEW FLOOR PLAN OF WORK AREA, LOWER FLOOR

- SEE REVISED DRAWINGS MARKED REVISION B, DATED 9-25-17
- ADDED NOTES ABOUT FIRE BARRIER WALLS AROUND RECORDS ROOM.

DRAWING – A-GM-06 - TYPICAL DETAILS AT RAISED FLOOR & PASS WINDOW AT RECORDS ROOM (R102)

- THE PASS WINDOW BETWEEN THE RECORDS ROOM AND LOBBY
- DELETE THE 8 INCH HIGH X 16 INCH WIDE OPENING IN THE SECURITY GLASS BETWEEN THE RECORDS ROOM AND LOBBY. INSTALL SLIDE TOP TRANSACTION DRAWER MOUNTED IN COUNTER UNDER GLASS SO DOCUMENTS CAN BE SECURELY EXCHANGED BETWEEN THE TWO AREAS. THE TRANSACTION DRAWER SHALL BE 16 GA.. MIN., STAINLESS STEEL, 400 MM WIDE, 413 MM IN DEPTH AND 125MM IN HEIGHT. TRANSACTION DRAWER SHALL BE AS MANUFACTURED BY CRL OR CREATIVE INDUSTRIES OR EQUAL. PREPARE COUNTER AND TOPS AS REQUIRED TO INSTALL THE SLIDE DRAWER IN TOP OF COUNTER ON THE RECORDS ROOM AND LOBBY ROOM SIDES.

END OF ADDENDUM NO. ONE