


FIRE WALL LEGEND:



ONE HOUR FIRE BARRIER WALL. ALL NEW DOOR SYSTEMS IN FIRE BARRIER WALLS SHALL BE 20 MINUTE FIRE RATED SYSTEMS UNLESS NOTED OTHERWISE. ALL FIRE BARRIER WALLS SHALL EXTEND TO BOTTOM SIDE OF FLOOR ABOVE OR SHALL EXTEND 4 INCHES MINIMUM ABOVE FIRE RATED CEILINGS. ALL PENETRATIONS IN FIRE BARRIER WALLS SHALL FIRE SEAL AROUND PERIMETER OF PENETRATION.

FIRE PENETRATION SEALS:

UL ONE HOUR WALL PENETRATION SEAL: W-L-1085 OR W-L-1084.

UL ONE HOUR DUCT PENETRATION SEAL: W-L-7003 OR W-L-7006.


FIRE WALL DELINEATION

1/8" = 1'-0"

A-GM-05

PARTIAL RENOVATION OF LOWER FLOOR
GUNTERSVILLE MUNICIPAL BUILDING
FOR
THE CITY OF GUNTERSVILLE, ALABAMA

Emmett D. Smith and Associates, Architect, P.C. - P.O. Box 171 Guntersville, Ala. 35976 - Phone (205) 531-3749



5450

REVISIONS

A FOR BIDS

DATE

08/28/17

BY

E.D. SMITH

CHECKED

SHEET NO.

A-GM-05

THIS DOCUMENT IS THE PROPERTY OF EMMETT D. SMITH & ASSOCIATES, ARCHITECT, P.C. AND IS NOT TO BE REPRODUCED, COPIED, OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, WITHOUT THE WRITTEN PERMISSION OF EMMETT D. SMITH & ASSOCIATES, ARCHITECT, P.C.

DRAWING SIZE