SECTION 09 6513

RESILIENT BASE

PART 1 - GENERAL

1.1 SUMMARY

A. Section Includes:
   1. Resilient wall base.

B. Related Sections:
   1. Division 01: Administrative, procedural, and temporary work requirements.

1.2 REFERENCES

A. ASTM International (ASTM) F1861 - Standard Specification for Resilient Wall Base.

1.3 SUBMITTALS

A. Submittals for Review:
   Color Samples:

1.4 MAINTENANCE

A. Extra Materials: 10 linear feet of each profile and color.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

A. Acceptable Manufacturers:
   1. Allstate Rubber Corp. (www.allstaterubber.com)
   2. Armstrong World Industries. (www.armstrongfloors.com)
   3. Burke Industries, Inc. (www.burkemercer.com)
   4. Johnsonite, Inc. (www.johnsonite.com)
   5. Roppe Corp. (www.roppe.com)
   6. Or equal

2.2 MATERIALS

A. Resilient Base:
   1. Type: ASTM F1861, thermoplastic rubber or thermoplastic vinyl.
   2. Thickness: 0.125 inch.
   3. Profile: Coved.
   4. Height: 4 inches.
   5. Length: Continuous rolls.
   6. Color: To be selected from manufacturer's full color range.
   7. Finish: Matte.
   8. End units and outside corners: Preformed; profile, size, and color to match base.

2.3 ACCESSORIES

A. Adhesive:
   1. Water based, waterproof, recommended by base manufacturer.

2.

PART 3 - EXECUTION

3.1 PREPARATION

A. Prepare surfaces to receive base:
   1. Remove materials that could interfere with adhesion.
   2. Fill low spots with patching compound; finish flush with adjacent surface.
   3. Remove high spots, ridges and nibs.

3.2 INSTALLATION

A. Apply adhesive continuously to back of base.

B. Maintain top edge true to line and bottom edge in continuous contact with floor. Butt joints tight; butt base tight to adjacent construction.

C. Do not install pieces less than 6 inches long.

D. Miter and butt inside corners.

E. At outside corners install preformed corner pieces.

F. At exposed ends, install pre-molded units.

G. Scribe to door frames and other interruptions.

END OF SECTION

©2009, SpexPlus™
Dec 2009